

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 6911-0410:0175

**CATEGORY:** Voice Communication Systems Control Units

**LISTEE:** Hochiki America, 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268  
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268  
Email: mum@hochiki.com

**DESIGN:** Models FNV-MP and FNV-DP audio adjunct/voice evacuation systems. The FNV-MP is the master panel in the system while the FNV-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FNV-PWR2A: Power Supply  
FNV-MFP: Master Fire Phone Card  
FNV-DCC : Data Communication Control Card  
FNV-ASC : Audio System Control Card  
FNV-SSC : Switch Scan Card  
FNV-MMC : Microphone Master Control Card  
FNV-IOI : Input/Output Card  
FNV-SLC : Switch and LED Card  
FNV-MFH : Master Fire Phone Handset Card  
FNV-MBR :Motherboard Card  
FNV-AMI : Audio Module Interface Card  
FNV-FPI : Motherboard/Relay Card  
FNV-25E, -50E or -100E : Audio Adjunct Systems\*

**RATING:** 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as voice communication/evacuation/relocation/paging system for use with separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLF:** 6911-1446:0103

\*Corrected 03-14-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **March 14, 2011**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division