

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7150-0410:0162

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268
Email: mum@hochiki.com

DESIGN: Models HPS-SAH, HPS/SAK, HPS-DAH, HPS-DAH/S, and HPS-SAH-WP with or without the suffix DA-C non-coded manual pull stations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed compatible fire alarm control units. Model HPS-SAH-WP is suitable for outdoor use. Refer to listee's Installation Instruction Manual for details.

* These manual pull boxes do not meet the requirements of UL Standard 38, 1999 Edition and California amendments.

XLF: 7150-1039:0101

*Updated 6-22-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division