

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7260-0410:0172

**CATEGORY:** 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268  
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268  
Email: mum@hochiki.com

**DESIGN:** Model SPC-24 Projected Beam, Smoke-Automatic Fire Detector. Unit consists of one emitter unit and one receiver unit. Refer to listee's printed data sheet for additional product description and operational consideration.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL Label

**APPROVAL:** Listed as beam smoke detectors for use with separately listed compatible fire alarm control units.

**NOTE:**



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*