

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7270-0410:0151

Page 1 of 1

**CATEGORY:** 7270 -- HEAT DETECTOR

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268  
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268  
Email: mum@hochiki.com

**DESIGN:** Models DCD-135 and DCD-190, fixed temperature and rate of rise heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Temperature: DCD-135: 135 F  
DCD-190: 190 F

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, rating and UL label.

**APPROVAL:** Listed as fixed temperature and rate of rise heat detector for use listed bases (CSFM Listing No. 7300-0410:132) and separately listed fire alarm control units.

\*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*