

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0107

Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268
Email: mum@hochiki.com

DESIGN: Models SLG-12, SLG-24, SLG-24FH, SLG-24F, SLK-12, SLK-24F, SLK-24FH, SLK-24FB, SLK-24FL, SLK-24FLB, SLK-835, SLK-835H, SLR-835, SLR-835W, SLR-835B-2, SLR-835B-4, SLR-835B-2W, SLR-835B-4W, SLR-24, SLR-24H, SLR-24V, *SLR-24VN, SLR-835H, SLR-835HW, SLR-835BH-2, SLR-835BH-2W, SLR-835BH-4, SLR-835BH-4W photoelectric type smoke detectors. Unit with suffix -H or -FH employs a supplemental heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC and 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed compatible fire alarm control units when used in conjunction with listee's listed bases (CSFM Listing No. 7300-0410:132). Models with supplemental heat sensor are not approved for use in lieu of required heat detectors.

NOTE: Formerly 7257-0410:107

*Rev 2-14-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division