

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7272-0410:0174

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268
Email: mum@hochiki.com

DESIGN: Models SLV-24, SLV-24V, SLV-24N and SLV-24M* Conventional, Photoelectric Type Smoke Detectors. Detectors are for use with listed Models NS4-220, NS4-224, NS6-220, NS6-224, HSC-4R, HSC-220R, and HSC-224R Bases. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with listed bases as shown in "DESIGN" and compatible listed fire alarm control units.

3-19-2008



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division