

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0160 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268
Email: mum@hochiki.com

DESIGN: Models SBC-2, -2R, -4/12, -4/24 detector sounder base. The use of suffix "W" indicates the color white. Unit SBC-2R employs a relay. SBC-4 models employ extra output leads for connection to a control panel initiating loop. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as detector base for use with separately listed functionally and electrically compatible fire alarm control units. Designed specifically for use with listee's Models SIJ-24 (CSFM Listing No. 7271-0410:135) Ionization Smoke Detector or Models SLR-24V, SLR-835 (CSFM Listing No. 7272-0410:107) Photoelectric Smoke Detector. Refer to listee's Installation Instruction Manual for details.

NOTE: These appliances can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

10-27-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division