

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0410:0161 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Hochiki America Corporation 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268  
Contact: Michael Um (714) 670-3248 Fax (714) 522-2268  
Email: mum@hochiki.com

**DESIGN:** Model ASB detector sounder base. Unit has an integral audible signal for use with spot-type detector units. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a detector base for use with separately listed functionally and electrically compatible fire alarm control units. Designed specifically for use with listee's Model ALG-V (CSFM Listing No. 7272-0410:149) Photoelectric Smoke Detector; Model AIE-EA (CSFM Listing No. 7271-0410:148) Ionization Smoke Detector; or Model ATG-EA (CSFM Listing No. 7270-0410:147) Heat Detector. Refer to listee's Installation Instruction Manual for details.

**NOTE:** These appliances can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

8-24-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*